

Key to Disability Access Terms – User Version

ACCESSIBLE PARKING AND ENTRANCE (Exterior Route)

Standard Accessible Parking

1. A parking space that is at least eight feet wide **(pg.2.Q#1)**
2. With an adjoining access aisle at least five feet wide
3. With signage displaying the international symbol of accessibility **(pg.2.Q#1)**
4. All designated parking spaces are on the shortest route of travel to the building's accessible entrance **(pg.2.Q #4)**

Van Accessible Parking

1. A parking space that is at least eight feet wide **(pg.2.Q#2)**
2. With an adjoining access aisle at least eight feet wide **(pg.2.Q#1,2,3)**
3. With signage displaying the international symbol of accessibility and the words "Van Accessible"
4. There are 98 inches of vertical clearance available for lift-equipped vans **(pg.2.Q#3)**
5. All designated parking spaces are on the shortest route of travel to an accessible entrance **(pg.2.Q#4)**

Accessible Path of Travel (applies from parking area to entrance)

1. A stable, firm, and slip resistant pathway **(pg.4.Q#2)**
2. The route leading to the facility is at least 36 unobstructed inches wide **(pg.4.Q#3)**
3. All curbs on the route of travel have curb ramps **(pg.4.Q#4)**
4. Ramps or other means of access provided where there are level changes greater than ½" **(pg.4.Q#5)**

Accessible Building Entrance (Main Exterior Route)

1. Doorway entry at least 32 clear inches width **(pg.5.Q#8)**
2. There is at least 18 inches of clear, unobstructed wall space adjacent to the door or automatic doors **(pg.5. Q#9)**

3. Handle or control can be used with a closed fist. For example, a lever handle and/or push button control is usable; a round doorknob is not usable. **(pg.9.Q#2)**

ACCESSIBLE INTERIOR (The paths to the waiting area, restrooms, and exam areas)

Accessible Interior doors, defined as

1. When the door is opened to 90 degrees, there is a clear opening width of at least 32 inches **(pg.9.Q#1 bottom of page)**
2. Handle that can be used with a closed fist. For example, a lever handle is usable; a round doorknob is not usable. **(pg.10.Q#5)**

Accessible Waiting Area

1. There is space for a person in a wheelchair to wait without blocking the clear width of aisle **(pg.13.Q#2 or #1 depending on version)**

Maneuvering Space

1. A minimum clear width of 36" for the entire route of travel **(pg.14.Q#1)**
2. There is a 5 foot circle or T-shaped space to reverse direction **(pg14.Q#3)**

Accessible Route

1. Stable, firm, slip-resistant surfaces **(pg.15.Q#7)**
2. In passageways through public areas, all obstacles (e.g. fire extinguishers) are located within 27 inches of the floor or higher than 80 inches and protrude less than 4 inches from the wall. **(pg.15.Q#8)**

Accessible Check-in Counter

1. The tops of tables or counters are between 28 and 34 inches high **(pg.13.Q#1)**

ACCESSIBLE RESTROOM (located in lobby and waiting area)

Accessible Doors (entry and stall doors)

1. Doorway when open 90 degrees, there is at least 32 inches clear width (**pg.22.Q#4 & pg.26.Q#2**)
2. Handle that can be used with a closed fist. For example, a lever handle is usable; a round doorknob is not usable. **(pg.22.#5& pg.26.Q#1)**

Accessible Turning Space

1. A T-shaped clear floor space or one that is 60" in diameter for a wheelchair to make a 180° turn **(pg.23.Q #7)**
2. There is at least 18 inches of clear space from the center of the toilet to the wall **(pg.26.Q#20)**
3. Toilet Stalls: There is a designated stall with a clear floor space of at least 5 feet long by 5 feet wide or a stall that is either 36 by 69 inches or 48 inches by 69 inches **(pg.27.Q#3/#4)**
4. For toilet Rooms: Where the toilet is approached from the front at least 48 inches wide by 56 inches long clear floor space from the center **(pg28.Q#1)**. Where toilet is approached from the side and there is a sink alongside the toilet, there is a clear floor space of at least 48 inches wide by 56 inches long **(pg28.Q#2)**. Where there is no sink alongside the toilet, there is a clear floor space of at least 60 inches wide by 56 inches long. **(pg28.Q #3)**

Accessible toilet, fixtures and sink

1. There is a 36 inches wide unobstructed path to all fixtures **(pg.23.Q#8)**
2. Sink rim is no higher than 34inches **(pg.24.Q#12)**
3. Sink handles that can be used with a closed fist **(pg.24.Q#13)**
4. The highest operable part of all dispensers and hand dryers is no higher than 48 inches **(pg.24.Q#14)**
5. All dispensers and hand dryers are operable with a single closed fist **(pg.25.#15)**

6. There are 2 horizontal grab bars: one on the wall behind the toilet and one on the side wall nearest to the toilet in the designated stall/toilet room. **(pg.25Q#17)**
7. Toilet seat measures 17" to 19" high **(pg.25#18)**

ACCESSIBLE MAMMOGRAPHY ROOM & MACHINE

Accessible Dressing Area

1. The dressing room is located on an accessible route? **(pg.33.Q#1)**
2. When access is swinging or sliding door or curtain, it has a T-shaped clear floor space or one that is 60" in diameter for a wheelchair to make a 180 degree turn?**(pg.33.Q#2)**
3. Bench is a least 48 inches wide, 18 inches high and 24 inches deep? **(pg.34.Q#5,6,7 - question & page vary depending on version)**

Accessible Mammography Room

1. Is on an accessible route(**pg.34.Q #1)**
2. A minimum clear width of 36 inches for the entire route of travel
3. No protruding objects that reduce the clear width of travel
4. The machine has a T-shaped clear floor space or one that is 60 inches in diameter for a wheelchair to make a 180° turn on the side of the mammography machine with the x-ray plate **(pg.35.Q#4)**

Accessible Mammography Machine

1. The machine has a positioning chair with a braking device and adjustable arm? **(Pg.35.Q #2)**
2. The machine has a breast platform that lowers to a height of 24-27 inches above the floor to the top side of the platform **(pg.35.Q#3)**