

M-OHCUP Quick Reference Guide

For more information on the accessibility questions and diagrams, please see **(page and question #)** in the Mammography-Outpatient Health Care Usability Profile v4OR

Accessible Parking and Entrance - exterior route

Standard Accessible Parking:

1. A parking space that is at least eight feet wide
2. With an adjoining access aisle at least five feet wide
3. With signage displaying the international symbol of accessibility **(pg.3.Q#1)**
4. All designated parking spaces are on the shortest route of travel to the building's accessible entrance **(pg.4.Q#4)**

Van Accessible Parking

1. A parking space that is at least eight feet wide **(pg.3.Q#2)**
2. With an adjoining access aisle at least eight feet wide **(pg.3.Q#2)**
3. With signage displaying the international symbol of accessibility AND the words "Van Accessible"
4. There are 98 inches of vertical clearance available for lift-equipped vans **(pg.2.Q#3)**
5. All designated parking spaces are on the shortest route of travel to an accessible entrance **(pg.2.Q#4)**

Accessible Path of Travel- applies from parking area to entrance of building

1. A stable, firm and slip resistant pathway **(pg.5.Q#9)**
2. The route leading to the facility is at least 36 unobstructed inches wide **(pg.5.Q#10)**
3. All curbs on the route of travel have curb ramps **(pg.6.Q#11)**
4. Ramps or other means of access provided where there are level changes greater than ½ inch **(pg.6.Q#11)**

Accessible Building Entrance

1. Doorway entry at least 32 inches clear opening **(pg.6.Q#15)**
2. There is at least 18 inches of clear, unobstructed wall space adjacent to the door **(pg.6.Q#16)**
3. All handles, locks, and controls can be used with a single closed fist. For example, a lever handle and/or push button control is usable; a round doorknob is not usable. **(pg.15.Q#43)**

M-OHCUP Quick Reference Guide

For more information on the accessibility questions and diagrams, please see **(page and question #)** in the Mammography-Outpatient Health Care Usability Profile v4OR

Accessible Interior - including paths to the waiting area, restrooms and exam area

Accessible Interior Doors- within the clinic building excluding the entrance doors

1. When a door is opened to 90 degrees, there is a clear opening width of at least 32 inches **(pg.14.Q#39)**
2. All handles, locks, and controls can be used with a single closed fist. For example, a lever handle and/or push button control is usable; a round doorknob is not usable. **(pg.15.Q#43)**

Accessible Waiting Area

1. There is space for a person in a wheelchair to wait without blocking the clear width of any aisles **(pg.18.Q#55)**

Accessible Maneuvering Space- route of travel to clinic services

1. Minimum of 36 unobstructed inches wide for the entire route of travel **(pg.20.Q#58)**
2. There is a 60 inch diameter circle or T-shaped** space to reverse direction **(pg.20.Q#60)**

Accessible Route

1. In passageways through public areas, all obstacles (e.g. fire extinguishers) are located between 27 inches and 80 inches from the floor, and protrude less than 4 inches from the wall **(pg.21.Q#63)**
2. Stable, firm and slip resistant surfaces, carpeting is securely attached along edges **(pg.21.Q#64)**

Accessible Check-In Counter

1. The tops of table or counters are between 28 and 34 inches high **(pg.19.Q#56)**

** T-shaped space: 36 inches wide each direction and 60 inches minimum depth

M-OHCUP Quick Reference Guide

For more information on the accessibility questions and diagrams, please see **(page and question #)** in the Mammography-Outpatient Health Care Usability Profile v4OR

Accessible Restroom - assess restroom located nearby to mammography area

Accessible Doors- entry AND stall doors

1. When door is open 90 degrees, there is at least 32 inches clear width **(pg.31.Q#95)**
2. All handles, locks, and controls can be used with a single closed fist. For example, a lever handle and/or push button control is usable; a round doorknob is not usable. **(pg.31.Q#96)**

Accessible Route and Turning Space

1. The entry is large enough for a wheelchair to enter, turn around and exit; T-shaped** clear floor space or one that is 60 inches in diameter **(pg.32.Q#98)**
2. There is at least 18 inches of clear space from the center of the toilet to the wall(s) on either side **(pg.35.Q#110)**
3. Toilet Stalls: There is a designated stall with a clear floor space of at least 5 feet long by 5 feet wide, or a stall that is either 36 inches by 69 inches or 48 inches by 69 inches **(pg.37.Q#114 and pg.38.Q#115)**
4. Toilet Rooms: Where the toilet is approached from the front and there is a sink alongside the toilet, there is clear floor space of at least 48 inches wide by 66 inches long **(pg.39.Q#117)**
5. Toilet Rooms: Where the toilet is approached from the side and there is a sink alongside the toilet, there is clear floor space of at least 48 inches wide by 56 inches long **(pg.39.Q#118)**
6. Toilet Rooms: Where there is no sink alongside the toilet, there is a clear floor space of at least 60 inches wide by 56 inches long **(pg.39.Q#119)**

Accessible Toilet, Fixtures and Sink

1. There is a 36 unobstructed inches wide path to all fixtures (e.g. sink, soap dispensers) **(pg.32.Q#99)**
2. The sink rim is no higher than 32 inches **(pg.33.Q#103)**
3. Sink handles can be used with a single closed fist **(pg.33.Q#104)**
4. The highest operable part of all dispensers and hand dryers is no higher than 48 inches **(pg.33.Q#105)**
5. All dispensers and hand dryers can be used with a single closed fist (pull-down paper-towel dispensers and many seat-cover dispensers are usually not accessible by this criteria) **(pg.34.Q#106)**
6. There are two **horizontal** grab bars: one on the wall behind the toilet and one on the side wall nearest the toilet in the designated stall/toilet room **(pg.34.Q#108)**
7. Toilet seat is 17-19 inches high **(pg.35.Q#109)**

** T-shaped space: 36 inches wide each direction and 60 inches minimum depth

M-OHCUP Quick Reference Guide

For more information on the accessibility questions and diagrams, please see **(page and question #)** in the Mammography-Outpatient Health Care Usability Profile v4OR

Accessible Mammography/Dressing Room & Machine

Accessible Dressing Room

1. The accessible dressing room is located on an accessible route **(pg.45.Q#137)**
2. Dressing room has a T-shaped** clear floor space or one that is 60 inches in diameter for a wheelchair to make a 180 degree turn **(pg.45.Q#138)**
3. Room has a bench that is at least 42 inches wide, 17 inches high, 20 inches deep **(pg.46.Q#141-143)**

Accessible Mammography Room

1. The passageway from the waiting area to the designated exam room is at least 36 unobstructed inches wide **(pg.42.Q#130)**
2. Mammography room has a T-shaped** clear floor space or 60 inch diameter circle for a wheelchair to make a 180 degree turn

Accessible Mammography Machine

1. The machine has a positioning chair with a braking device and adjustable arm **(pg.47.Q#145)**
2. The machine has a breast platform that lowers to a height of 24-27 inches above the floor to the top side of the platform **(pg.47.Q#146)**
3. The machine has a 60 inch diameter circle of clear floor space or a T-shaped** clear floor space adjacent to the machine **(pg.47.Q#147)**

** T-shaped space: 36 inches wide each direction and 60 inches minimum depth